



Braintree Town Council

ORDER NO: 14 013

DATE FILED: MARCH 3, 2014

REQUEST OF: NATIONAL GRID

National Grid hereby respectfully requests your consent to the locations of mains as hereinafter described for the transmission and distribution of gas in and under the following public streets, lanes, highways, and places of the Town of Braintree and of the pipes, valves, governors, manholes and other structures, fixtures and appurtenances designed or intended to protect or operate said mains and accomplish the objects of said Company; and the digging up and opening the ground to lay or place same:

To install and maintain approximately 30 feet, more or less, of 2 inch gas main in Woodedge Avenue, Braintree from the existing 2 inch gas main near house #50, westerly to house #55 for a new gas service with staff recommendations: "The proposed location is not under the moratorium, but was totally reconstructed in 2003. The proposed route runs very close to concrete curbing in good condition and through a drainage catch basin. The concrete curbing would be very difficult to reset, repair or replace with a matching curb, so if any is damaged, the full length along the trench would have to be replaced with our current standard, Type VA granite curbing. The sidewalk would also have to be saw cut and repaired. However, the main extension has to be moved out to avoid the catch basin anyway, so it should also be moved away from the curbing. If this change is made, we recommend that the petition be granted under the normal conditions, with emphasis on the requirements that the gas main be laid outside of the trench of the water main in service and that the trench pavement not be left low for any length of time."

YEAS: Bowes, Clifford, Hume, Kokoros, Mullaney, O'Brien, Owens, Powers, Ryan

NAYS: NONE

ABSENT: NONE

PASSED IN COUNCIL: APRIL 1, 2014

A True Record, Attest:


Debra J. Starr, Acting Town Clerk

